

Plant Capacity:	2.8 MW electricity, 3.4 MW heat, 70,000 TPY
Foul Air Sources:	Receiving area, storage tanks
Odor Treatment Technology:	Biofilter
Treatment Media:	Biosorbents
Empty Bed Residence Time:	34 seconds
Foul Air Flow Rate:	12,000 CFM
Inlet Odour Concentration:	20,000 OU
Required Odor Removal:	<1.0 OU beyond the property line (<2,000 OU stack outlet)
Commissioned:	2014

