

Plant Capacity:	6.0 MGD
Foul Air Sources:	Influent pumping station and influent box
Odor Treatment Technology:	Biotrickling filter
Treatment Media:	PUF
Empty Bed Residence Time:	10.0 seconds
Foul Air Flow Rate:	9,965 CFM
Design H <sub>2</sub> S Concentration:	100 ppm average 250 ppm peak
Design H <sub>2</sub> S Removal Performance:	99% at average inlet 98% at peak inlet
Commissioned:	2014

